Board of County Commissioners • Escambia County, Florida

Paul R. Nobles/Purchasing Manager
Office of Purchasing

February 24, 2018

To: All Known Prospective Bidders

Addendum Number 1:

Re: CR 297A at Kingsfield Road (CR186) Intersection Improvements
Specification Number: PD 17-18.029

All:

We recently sent you an Invitation to Bid on the above-mentioned specification.

This Addendum Number 1 provides for:

1. **Response to Questions/Clarifications**

   A. Utility Notes listed on sheet 3 state that contractor shall notify utility owner prior to construction to spot/verify their utility. There are numerous locations where existing utilities either cross or parallel proposed storm drainage. Will relocation of utilities be provided by the owner of each utility?

      Response – Yes

   B. Where is the trench underdrain located?

      Response – This is a "just in case item" if there is groundwater issues

   C. MH #3 & #5 appear to have a doubling dipping effect as the structure bottoms fall under bid item #40 and the entire MH in bid item #48. Can you clarify which bid item these two MH's should be submitted on?

      Response – Please split the cost between the line items.

2. **Revised Bid Form**

   Escambia County will utilize our existing signalization contract to have Ingram install the signalization equipment to help with the time constraints. The awarded contractor shall coordinate with Ingram and be responsible for any necessary earthwork for Ingram to successfully install the signalization.

Bid Item 8 includes the 2” asphalt as part of the 14445 SY with the remaining being the overbuild.

Bid Item 78 is to be bid in concordance with Sheet 64 FLAT-BOTTOM CONCRETE SWALE DETAIL note 4. It is not tied concrete block. Tied concrete block is not in this bid.

This Addendum Number 1 is furnished to all known prospective Bidders. Please sign and return one copy of this Addendum, with original signature, with your bid as an acknowledgement of you having received same. You may photo copy for your record.

Sincerely,

Paul R. Nobles
Purchasing Manager

Acknowledgement of Receipt of Addendum 1:

SIGNED: _____

COMPANY: _____