



## Board of County Commissioners • Escambia County, Florida

Paul R. Nobles/Purchasing Manager  
Office of Purchasing

February 1, 2018

To: All Known Prospective Bidders

### **Addendum Number 2:**

Re: Olive Road East Multi Lane Reconstruction and Drainage Project Phase 2 (Yancey Avenue to Johnson Avenue) Construction  
Specification Number: PD 17-18.020

All:

We recently sent you an Invitation to Bid on the above-mentioned specification.

This Addendum Number 2 provides for clarification and response to questions asked.

### **Response to Questions**

1. *Pay Item Note #2 on sheet 23 of 194 says to include the removal of existing drainage features in clearing and grubbing, yet the plans do not provide the dimensions of existing storm system. Please provide existing pipe dimensions of stormwater system to be removed.*

**Response:** The lengths and limits of the existing drainage system are shown on the Roadway Plan Sheets. Per General Note 17, all existing drainage is to be removed unless noted on the Plan Sheets. Refer to the Temporary Traffic Control Plan (TTCP) Sheets for construction sequence, temporary drainage, and another clear view of the existing drainage system.


2. *Do we know what type of material PVC or DIP the existing water lines are where the insert valves will be located?*

**Response:** The following list are the roads, size, and material at the insertion valve locations based on our GIS maps:

- Yancey, 6" Cement Asbestos
- Stark, 4" PVC
- Excelsior, 4" Cement Asbestos
- Six Pence, 6" Cement Asbestos
- Boyd, 6" Cement Asbestos

This Addendum Number 2 is furnished to all known prospective Bidders. Please sign and return one copy of this Addendum, with original signature, with your bid as an acknowledgement of you having received same. You may photo copy for your record.

Sincerely,



Emily D. Weddington, CPPB  
Purchasing Coordinator

Acknowledgement of Receipt of Addendum 2:

SIGNED: \_\_\_\_\_

COMPANY: \_\_\_\_\_