



Paul R. Nobles/Purchasing Manager
Office of Purchasing

February 13, 2018

To: All Known Prospective Bidders

Addendum Number 7:

Re: Olive Road East Multi Lane Reconstruction and Drainage Project Phase 2 (Yancey Avenue to Johnson Avenue) Construction
Specification Number: PD 17-18.020

All:

We recently sent you an Invitation to Bid on the above-mentioned specification.

This Addendum Number 7 provides for:

Questions/Answers

Below are questions asked by contractors in Addendum 6, further clarified. Answers below are for bidding clarity and do not reflect any plan changes or bid item changes:

1. *Note 3 on utility plans states that all manhole adjusts are to be included in other pay items. Usually there is a pay item for valve and manhole adjusts. Please provide a quantity and line item for valve adjustments and one for manhole adjustments.*
Answer: The quantities and notes for the proposed water line were provided to DRMP by ECUA. As the note states, the contractor must cover the cost of these items with other pay items. An additional line item will not be provided. All water line costs are under the jurisdiction of ECUA Engineering staff, ECUA directives, and ECUA technical specifications. The costs for adjusting manholes and valves would be most appropriate to include in the waterline pay items.
2. *Note 17 of the Utility plans states that we are to field adjust to avoid conflicts with existing utilities, yet no 45's have been accounted for potential areas of conflict within the pay items. Have enough 45's been included in the pay items to address these conflicts? If not, please provide an updated quantity because it is not the contractors responsibility to guess on how many conflicts "may" occur.*
Answer: The quantities and notes for the proposed water main were provided to DRMP by ECUA. The water line was laid out using the best available information. As the water line is constructed, conflicts may or may not arise. It is up to the contractor to determine how

he/she may quantify unforeseen conflicts prior to construction. If warranted water line conflicts arise during construction due to unforeseen conditions, a change order would be the appropriate method to accommodate such conflicts. Since the County and ECUA have a cost sharing agreement for the waterline work on this project, ECUA concurrence of all water line change order items would also be necessary.

This Addendum Number 7 is furnished to all known prospective Bidders. Please sign and return one copy of this Addendum, with original signature, with your bid as an acknowledgement of you having received same. You may photo copy for your record.

Sincerely,



Emily D. Weddington, CPPB
Purchasing Coordinator

Acknowledgement of Receipt of Addendum 7:

SIGNED: _____

COMPANY: _____