

**BOARD OF COUNTY COMMISSIONERS  
ESCAMBIA COUNTY, FLORIDA**

**OFFICE OF PURCHASING**

213 PALAFOX PLACE, 2<sup>nd</sup> Floor  
P.O. BOX 1591  
PENSACOLA, FL 32591-1591  
TELEPHONE (850)595-4980  
(SUNCOM) 695-4980  
TELEFAX (850)595-4805

<http://www.myescambia.com/business/solicitations>

CLAUDIA SIMMONS  
*Purchasing Manager*



August 18, 2016

To: All Known Prospective Bidders

**ADDENDUM NUMBER 3:**

Re: Escambia County Main Jail Nurse Station  
Specification Number: PD 15-16.079

Bidders:

We recently sent you an Invitation to Bid on the above mentioned specification.

This Addendum #3 provides for responses to the following questions:

Question - On page A701 of the drawings for the door schedule they have the new doors listed as 1 ¾" thick. In the specifications they say 2" thick. Security Hollow Metal doors are always 2" thick. Can you please let me know if you would like the doors 2" thick or 1 ¾" thick. The Southern lock you guys are using can be used with a 1 ¾" thick door or a 2" thick door.

Response - All permanent doors shall be 2" thick.

Question - Since we are reusing the existing frames you currently have, what is the door thickness of your current doors?

Response - 2", field verify existing openings prior to ordering doors.

Question - For the door tag numbers that you are using the existing frames and hardware, does your existing doors have food/cuff port assemblies now on them? If so, can we reuse the existing food pass locks or do we need to provide new locks. Please let me know.

Response - Provide new food/cuff ports per construction documents.

Question - For the first Phase you guys are setting up the temp door and wall. Will you guys be using a door unit and hardware you already have or will this need to be provided.

Response - Coordinate with General Contractor.

Question - The Security Access Panels in the Ceiling on drawing A701 says the locks are to have Best IC Cylinders. Can you tell me your existing lock model number you are currently using for your Security Access Panels so we ensure we figure having these units keyed to your existing key system.

Response - Best Interchangeable cores are standard 1C small format core, 7-pin, TB keyway, 626 finish. Specific keying for all new locks shall be coordinated to match owner's existing masterkey system.

Question - We could have the Security Access ceiling panels manufactured to take the same lock and use the same keying as the Cell Recessed Receptacles cover which would minimize the different lock types and keys. Let me know if you guys would be interested in that.

Response - Bid as shown in construction documents.

Question - Also if we are to provide you the existing keying system on the spec section you have southern and Folgers listed for the food Pass locks. Which lock do you have.

Response - Either is acceptable. Snap latch with thumbturn does not require a key.

Question - We will need to provide a complete new hardware set for the one new door frame and door, TAG 240A.

Response - Correct, lockset is described in Detention hardware Specification 111920 Paragraph 2.02.D.

Question - Also the Carbon steel Prison rated lockable cover for cell recessed receptacles...are you using Folgers line or Southern line locks.

Response - Folger Adam

Question - Also on the Security Door Specification you say "Is it intent that **ALL** security doors and frames are to be bullet resistant?" If so, it doesn't list what level for the BR. Trussbilt provide BR Level 3. Will this work?

Response - BR Level is not required. Meet Security Rating on hardware schedule.

Question - The specification calls for Training on the Hardware sets. Do you guys indeed need training?

Response - Training will not be not required.

This Addendum Number 3 is furnished to all known prospective Bidders. Please sign and return one copy of this Addendum, with original signature, with your proposal as an acknowledgement of your having received same. You may photo copy for your record.

Sincerely,



Paul Nobles, CPPO, CPPB, FCCM, FCN  
Purchasing Coordinator

SIGNED: \_\_\_\_\_

COMPANY: \_\_\_\_\_

PRN:ehw