

**BOARD OF COUNTY COMMISSIONERS  
ESCAMBIA COUNTY, FLORIDA**

**OFFICE OF PURCHASING**

213 PALAFOX PLACE, 2<sup>nd</sup> Floor  
P.O. BOX 1591  
PENSACOLA, FL 32591-1591  
TELEPHONE (850)595-4980  
(SUNCOM) 695-4980  
TELEFAX (850)595-4805

<http://www.myescambia.com/business/solicitations>



CLAUDIA SIMMONS  
*Purchasing Manager*

June 30, 2016

To: All Known Prospective Bidders

**ADDENDUM NUMBER 1:**

Re: Merlin Road Drainage Improvements Project  
Specification Number: PD 15-16.066

Bidders:

We recently sent you an Invitation to Bid on the above mentioned specification.

This Addendum #1 provides for:

**1. Revised Bid Form**

Question - Regarding the Merlin Drainage Improvements, could you take a look at the bid tab, item 34. Should that read unsuitables 1000 CY?

Revised bid form – see attached 1 page

Question - Regarding the Merlin Drainage Improvements, could you take a look at the bid tab, item 35.

Clarify - Not much curbing to be removed, Lump sum is sufficient.

**2. Clarifications**

Question - On number 31, can we get some information on the gas main, is it steel or polyethylene, and could you call out what exactly is to take place like a minimum footage?

Clarify - I have discussed this with Clint Chevat of Pensacola Energy. Any relocation of gas main will be done by Pensacola Energy. The main is 2" Polyethylene pipe. He does not anticipate any conflicts at this time. You may use this tab for coordination work with Pensacola Energy.

Question - Are we allowed to do the welding or fusing our self or does the owner need to be compensated for doing the relocation?

Clarify - See above

Question - Number 30, Could you also define what you want done with the force main?

Clarify - The engineer feels that the forcemain will be in conflict with the storm sewer at Meadson and Merlin. The forcemain will have to be rerouted.

Question - Also, what it is made of, some flow rates, and what hours we can down the system to do the off sets. If a vertical offset is needed, will we have to install an air release valve? If so, could we get a detail on the ARV?

Clarify - We do not have any additional information other than what is labeled on the plans. The Contractor will need to contact ECUA prior to any sanitary sewer construction activity. Any specifics regarding construction shall be per ECUA's specifications with proper notification given to the public regarding any stoppage of sewer service.

Question - On item 24, what signs are we to remove and replace? All of the signs on site?

Clarify - As needed, some have been moved prior.

Question - Item 23, could you specify where and what you want done with the water system?

Clarify - Relocation of any waterlines as needed per relocation of end sections or other. Plan notes state that any service line cut must be replaced to the main.

Question - Item 10, is this dewatering as in wellpointing, or what water is to be removed?

Clarify - Dewatering is covered under our technical specification Earthwork 2300-Part 3 Execution – 3.1. As discussed at the pre-bid, the end section at the lower end of the outlet may need to have water removed to meet compaction tests. For dewatering in general during construction, water is to be removed as needed.

Clarification - the quantity of sod should read 11,200 SY. Plan sheet 5 of 26 incorrectly reads 8,400 SY

This Addendum Number 1 is furnished to all known prospective Bidders. Please sign and return one copy of this Addendum, with original signature, with your proposal as an acknowledgement of your having received same. You may photo copy for your record.

Sincerely,

A handwritten signature in blue ink, appearing to be 'Paul Nobles', written over a horizontal line.

Paul Nobles, CPPO, CPPB, FCCM, FCN  
Purchasing Coordinator

SIGNED: \_\_\_\_\_

COMPANY: \_\_\_\_\_

PRN:abh

No	DESCRIPTION	QUANTITY	UNIT	UNIT COST	AMOUNT
29	REMOVE AND REPLACE SHRUBS (Includes Crepe Myrtle and Irrigation Adjustments)	1	LS		
30	ADJUST 6' SEWER FORCE MAIN	1	LS		
31	ADJUST 2" GAS MAIN	1	LS		
32	REMOVE AND REPLACE RAILROAD LANDSCAPE TIMBERS	1	LS		
33	POOL DISCHARGE DIVERSIONS	1	LS		
34	UNSUITABLES	1000	CY		
35	REMOVE AND REPLACE CURB	1	LS		
		TOTAL			\$ _____

If your company is located within a Community Redevelopment Area of Escambia County, Florida, please Indicate by marking an X in the blank (*Sec. 46-110.-Local Preference in Bidding*). Yes \_\_\_ No \_\_\_

**CONTRACTOR REQUIREMENTS**

Acknowledgment is hereby made of receipt of the following addenda issued during the bidding period:

Addendum No. \_\_\_\_\_ Date \_\_\_\_\_ Addendum No. \_\_\_\_\_ Date \_\_\_\_\_  
 Addendum No. \_\_\_\_\_ Date \_\_\_\_\_ Addendum No. \_\_\_\_\_ Date \_\_\_\_\_

**(PLEASE TYPE INFORMATION BELOW)**  
**SEAL IF BID IS BY CORPORATION**

State of Florida Department of State Certificate of Authority  
 Document Number \_\_\_\_\_

Bidder: \_\_\_\_\_

Occupational License No. \_\_\_\_\_

By: \_\_\_\_\_

Florida DBPR Contractor's License, Certification and/or  
 Registration No. \_\_\_\_\_

Signature: \_\_\_\_\_

Type of Contractor's License, Certification and/or  
 Registration \_\_\_\_\_

Title: \_\_\_\_\_

Address: \_\_\_\_\_

Expiration Date: \_\_\_\_\_

Person to contact concerning this bid:

Phone/Toll Free/Fax # \_\_\_\_\_

Terms of Payment  
 (Check one) Net 30 Days \_\_\_ 2% 10th Prox \_\_\_

E-Mail Address: \_\_\_\_\_

Home Page Address: \_\_\_\_\_

Will your company accept Escambia County Purchasing  
 Cards? Yes \_\_\_ No \_\_\_\_\_.

Person to contact for emergency service:

Will your company accept Escambia County Direct  
 Payment Vouchers? Yes \_\_\_ No \_\_\_\_\_.

Phone/Cell/Pager #: \_\_\_\_\_