



14' width

Drainage Easement-
replace culvert and
head walls

Drainage pipe opens to
overground flow into
ravine

16' width

20' width

Culvert needs
replacing- full of sand

Severe pavement
distress, alligator
cracking on Quintette,
need to remove and
repave at least 1000'
either side of the
intersection